

**ADDENDUM No. 1**

**February 15, 2022**

**Demolition-75 Barker Road, Whitmore Lake, MI 48189  
Northfield Township  
RFP # 22-001**

The following changes, additions, and/or clarifications to the Contract Documents shall be incorporated in said documents and shall be allowed for in the unit prices bid by the Contractor such that the unit prices indicated in the Bid Worksheet shall represent the conditions as set forth in the Contract Documents and this addendum. The bidder shall acknowledge the receipt of this addendum on page AD-2 of the Addendum and shall staple this addendum into the Contract Book.

This Addendum contains 16 pages.

**ADDITIONS AND CHANGES TO THE SPECIFICATIONS**

SECTION: Attachment 3

1. Supplemental information is being provided in the asbestos abatement report to include removal quantities.

**ACKNOWLEDGEMENT of RECEIPT OF ADDENDUM**

**ATTENTION:**

Our firm: \_\_\_\_\_

has received from Northfield Township

Addendum No. 1 for: **Demolition-75 Barker Road, Whitmore Lake, MI 48189**  
**Northfield Township**  
**RFP # 22-001**

Today, \_\_\_\_\_ (date) at \_\_\_\_\_ (time) a.m. / p.m. (circle one)

Signature of receiver: \_\_\_\_\_

Printed name of receiver: \_\_\_\_\_

Company name: \_\_\_\_\_

**End of Addendum 1**

**TABLE 1**

**Homogeneous Area Materials List**

**Table 1  
Homogeneous Area Materials List  
Former Northfield Township Fire Department**

HOMOGENEOUS AREAS		RESULTS	
HA#	MATERIAL DESCRIPTION	PLM ANALYTICAL	TOTAL QUANTITIES
01	Plaster-board system (Single-layer plaster, gypsum panel substrate), ceiling, w/troweled-on texture pattern	Plasterboard = NAD Drywall = NAD	-
02	Pipe straight insulation, brown paper layer w/black tar-paper inner lining ("duplex" type)	NAD	-
03	HVAC duct insulation, red fibrous matt w/grey plastic wrap	NAD	-
04	2' x 4' Ceiling panel, suspended, pinholes-lg. gouges pattern	NAD	-
05	2' x 4' Ceiling panel, suspended, pinholes-sm. pockmarks pattern	NAD	-
06	18" x 36" Ceiling panel, fastened, smooth pattern, lt. brown fibrous matrix	NAD	-
<b>07</b>	<b>9" x 9" Floor tile, grey w/white &amp; black streak-mottling, &amp; black mastic</b>	<b>Floor Tile = Chrysotile - 2%</b> Mastic = NAD	<b>101 SF</b>
<b>08</b>	<b>9" x 9" Floor tile, beige w/brown streak-mottling, &amp; black mastic</b>	<b>Floor Tile = Chrysotile - 5%</b> Mastic = Chrysotile - 5%	<b>55 SF</b>
<b>09</b>	<b>12" x 12" Floor tile, beige w/tan-grey mottle, &amp; yellow-tan adhesive/mastic</b>	<b>Floor Tile = Chrysotile - 2%</b> Mastic = NAD	<b>30 SF</b>
<b>10</b>	<b>12" x 12" Floor tile, brown w/white-tan-grey mottle, &amp; black mastic</b>	<b>Floor Tile = Chrysotile - 5%</b> Mastic = Chrysotile - 2%	<b>480 SF</b>
11	Vinyl sheet flooring, lt. grey mottle w/faux 9"x9" pattern	NAD	-
12	Vinyl sheet covering, countertops, grey w/white & dk. grey marbling, black felt backing, & adhesive	Vinyl Sheet = NAD Adhesive/Glue = NAD	-
13	Vinyl sheet covering, countertop, off-white w/grey & black random "confetti" pattern, grey felt backing, & adhesive	Vinyl Sheet = NAD Adhesive/Glue = NAD	-
14	Decorative wall panel, 1/4" hardboard, lt. grey w/blue-grey streak pattern, & constr. Adhesive	Wall Panel = NAD Drywall = NAD Adhesive/Glue = NAD	-
15	4" Vinyl cove base, tan, and adhesive	Cove Base = NAD Adhesive/Glue = NAD	-
16	4" Vinyl cove base, white, and adhesive	Cove Base = NAD Adhesive/Glue = NAD	-
17	Wallboard system (gypsum panel, joint-compound)	Drywall = NAD Joint Compound = NAD	-
18	Window glaze compound, off-white/lt. grey, brittle, chalky	NAD	-
19	Refractory cement, grey, cementitious	NAD	-
20	Concrete masonry unit (CMU wall block), grey	NAD	-
21	Mortar joint, for CMU (HA-20)	NAD	-
22	HVAC duct vibration dampener, black vinyl-coated fabric	NAD	-

**Table 1  
Homogeneous Area Materials List  
Former Northfield Township Fire Department**

HOMOGENEOUS AREAS		RESULTS	
HA#	MATERIAL DESCRIPTION	PLM ANALYTICAL	TOTAL QUANTITIES
23	Floor vapor barrier, black bituminous paper layer (underneath hardwood flooring)	NAD	-
24	4" Vinyl cove base, dk. grey, and adhesive	Cove Base = NAD Adhesive/Glue = NAD	-
25	<b>Vinyl sheet covering, tabletop &amp; cabinet shelf liner, beige/tan sm. mosaic pattern, w/grey felt backing</b>	<b>Chrysotile - 15%</b>	<b>12 SF</b>
26	<b>Sink under-coating, textured, lt. lavender</b>	<b>Chrysotile - 5%</b>	<b>3 Sinks</b>
27	Window gap insulation, fibrous batt w/paper & black coating	NAD	-
28	Attic insulation, loose blown-in, cellulosic, lt. brown, fibrous	NAD	-
29	Carpet adhesive, tan & <b>mastic, black</b>	Adhesive = NAD <b>Mastic = Chrysotile 10%</b>	<b>800 SF</b>
30	Carpet adhesive, yellow-tan	NAD	-
31	Floor leveling compound, grey, thin, w/residual adhesive & <b>mastic</b>	Glue = NAD Leveling Compound = NAD <b>Mastic = Chrysotile - 2%</b>	<b>500 SF</b>
32	<b>Residual floor mastic, black</b>	<b>Chrysotile - 2%</b>	<b>500 SF</b>
33	Sub-layer vinyl sheet flooring, tan w/grey felt backing & adhesive (below HA-11)	Vinyl Sheet = NAD Glue = NAD	-
34	Spray-foam sealant, yellow-orange	NAD	-
35	Exterior, doorframe caulk, off-white, semi-flexible	NAD	-
36	Exterior, window lintel caulk, off-white	NAD	-
37	Exterior, glass-block mortar joint, cementitious	NAD	-
38	Exterior, bulletin-board/notification panel frame caulk, grey	NAD	-
39	Exterior, window-frame caulk, lt. grey, flexible	NAD	-
40	<b>Exterior, window-frame caulk, grey/tan, brittle</b>	<b>Chrysotile - 2%</b>	<b>10 Large Windows and 3 Small Windows (205 LF)</b>
41	Wallboard system (gypsum panel, joint-compound)	Wallboard System = NAD Joint Compound = NAD	-
42	HVAC duct insulation, yellow fibrous matt w/grey plastic wrap	NAD	-
43	Slate roofing shingles, grey, striated matrix	NAD	-
44	Refractory compound, dk. grey	NAD	-

**Table 1  
Homogeneous Area Materials List  
Former Northfield Township Fire Department**

HOMOGENEOUS AREAS		RESULTS	
HA#	MATERIAL DESCRIPTION	PLM ANALYTICAL	TOTAL QUANTITIES
45	Skim-coat plaster surfacing on CMU wall	Skim Coat Plaster/FC = NAD Plaster/BC = NAD	-
--	<b>(1971 Bldg. Addition)</b>		
46	Wallboard system (gypsum panel, joint-compound)	Drywall = NAD Joint Compound = NAD	-
47	Wall cavity insulation, pink fibrous batt w/paper layer & black coating	NAD	-
48	1' x 1' Ceiling tile, adhered, w/groove pattern & brown adhesive	Ceiling Tile = NAD Adhesive/Glue Pod = NAD	-
49	Wall cavity insulation, yellow fibrous batt w/paper layer & black coating	NAD	-
50	Carpet adhesive, yellow-tan	NAD	-
51	Exterior, asphalt roofing shingles, w/grey grit	Asphalt Shingles w/ Grey = NAD Black Shingle = NAD	-
52	Exterior, bituminous sheet roof under-layment	NAD	-
53	Exterior, wall panel sheathing, fibrous, brown	NAD	-
54	Exterior, tar-paper vapor barrier	NAD	-
55	Exterior, window-frame caulk, off-white/lt. grey, semi-flexible	NAD	-

**Key: NAD = No Asbestos Detected**

**Shaded rows indicate materials that are assumed or tested positive for asbestos.**

**TABLE 2**

**Homogeneous Materials Sample Locations  
and Results**

**Table 2**  
**Homogeneous Materials Sample Locations and Results**  
**Former Northfield Township Fire Department**

HOMOGENEOUS AREAS		BULK SAMPLE LOCATIONS		ANALYTICAL
HA#	MATERIAL DESCRIPTION	SAMPLE #	SAMPLE LOCATION	PLM RESULTS
<b>(1955 Building)</b>				
01-A	Plaster-board system (Single-layer plaster, gypsum panel substrate), ceiling, w/troweled-on texture pattern	01-A	Garage area, S.	Plasterboard = NAD Drywall = NAD
01-B	Plaster-board system (Single-layer plaster, gypsum panel substrate), ceiling, w/troweled-on texture pattern	01-B	Garage area, S.	NAD, NAD
01-C	Plaster-board system (Single-layer plaster, gypsum panel substrate), ceiling, w/troweled-on texture pattern	01-C	Garage area, S.	NAD, NAD
02-A	Pipe straight insulation, brown paper layer w/black tar-paper inner lining (“duplex” type)	02-A	Garage area, S.	NAD
02-B	Pipe straight insulation, brown paper layer w/black tar-paper inner lining (“duplex” type)	02-B	Garage area, S.	NAD
02-C	Pipe straight insulation, brown paper layer w/black tar-paper inner lining (“duplex” type)	02-C	Garage area, S.	NAD
03-A	HVAC duct insulation, red fibrous matt w/grey plastic wrap	03-A	Garage area, E.-cent.	NAD
03-B	HVAC duct insulation, red fibrous matt w/grey plastic wrap	03-B	Garage area, E.-cent.	NAD
03-C	HVAC duct insulation, red fibrous matt w/grey plastic wrap	03-C	Garage area, E.-cent.	NAD
04-A	2' × 4' Ceiling panel, suspended, pinholes-lg. gouges pattern	04-A	Main office, cent.	NAD
04-B	2' × 4' Ceiling panel, suspended, pinholes-lg. gouges pattern	04-B	Main office, W.	NAD
05-A	2' × 4' Ceiling panel, suspended, pinholes-sm. pockmarks pattern	05-A	Main office, cent.	NAD



**Table 2**  
**Homogeneous Materials Sample Locations and Results**  
**Former Northfield Township Fire Department**

HOMOGENEOUS AREAS		BULK SAMPLE LOCATIONS		ANALYTICAL
HA#	MATERIAL DESCRIPTION	SAMPLE #	SAMPLE LOCATION	PLM RESULTS
05-B	2' × 4' Ceiling panel, suspended, pinholes-sm. pockmarks pattern	05-B	Main office, cent.	NAD
06-A	18" × 36" Ceiling panel, fastened, smooth pattern, lt. brown fibrous matrix	06-A	2nd fl., cent.	NAD
06-B	18" × 36" Ceiling panel, fastened, smooth pattern, lt. brown fibrous matrix	06-B	2nd fl., NE	NAD
07-A	9" × 9" Floor tile, grey w/white & black streak-mottling, & black mastic	07-A	Garage area, lavatory	FT = Chrysotile - 2% Mastic = NAD
07-B	9" × 9" Floor tile, grey w/white & black streak-mottling, & black mastic	07-B	Garage area, lavatory	N/A, NAD
08-A	9" × 9" Floor tile, beige w/brown streak-mottling, & black mastic	08-A	Garage area, SE, near side entry/exit	FT = Chrysotile - 5% Mastic = Chrysotile - 5%
08-B	9" × 9" Floor tile, beige w/brown streak-mottling, & black mastic	08-B	Garage area, SE, near side entry/exit	N/A
09-A	12" × 12" Floor tile, beige w/tan-grey mottle, & yellow-tan adhesive/mastic	09-A	Garage area, NE, near front entry/exit	FT = Chrysotile - 2% Mastic = NAD
09-B	12" × 12" Floor tile, beige w/tan-grey mottle, & yellow-tan adhesive/mastic	09-B	Garage area, NE, near front entry/exit	N/A, NAD
10-A	12" × 12" Floor tile, brown w/white-tan-grey mottle, & black mastic	10-A	2nd fl., S., hallway area	FT = Chrysotile - 5% Mastic = Chrysotile - 2%
10-B	12" × 12" Floor tile, brown w/white-tan-grey mottle, & black mastic	10-B	2nd fl., S., kitchen area	N/A
11-A	Vinyl sheet flooring, lt. grey mottle w/faux 9"×9" pattern	11-A	Main office area, lavatory	NAD
11-B	Vinyl sheet flooring, lt. grey mottle w/faux 9"×9" pattern	11-B	Main office area, lavatory	NAD
12-A	Vinyl sheet covering, countertops, grey w/white & dk. grey marbling, black felt backing, & adhesive	12-A	2nd fl., S., kitchen area	Vinyl Sheet = NAD Adhesive/Glue = NAD

**Table 2**  
**Homogeneous Materials Sample Locations and Results**  
**Former Northfield Township Fire Department**

HOMOGENEOUS AREAS		BULK SAMPLE LOCATIONS		ANALYTICAL
HA#	MATERIAL DESCRIPTION	SAMPLE #	SAMPLE LOCATION	PLM RESULTS
12-B	Vinyl sheet covering, countertops, grey w/white & dk. grey marbling, black backing, & adhesive	12-B	2nd fl., S., kitchen area	NAD, NAD
13-A	Vinyl sheet covering, countertop, off-white w/grey & black random "confetti" pattern, grey felt backing, & adhesive	13-A	2nd fl., SW, serving area	Vinyl Sheet = NAD Adhesive/Glue = NAD
13-B	Vinyl sheet covering, countertop, off-white w/grey & black random "confetti" pattern, grey felt backing, & adhesive	13-B	2nd fl., SW, serving area	NAD, NAD
14-A	Decorative wall panel, ¼" hardboard, lt. grey w/blue-grey streak pattern, & constr. Adhesive	14-A	Main office area, lavatory	Wall Panel = NAD Drywall = NAD Adhesive/Glue = NAD
14-B	Decorative wall panel, ¼" hardboard, lt. grey w/blue-grey streak pattern, & constr. Adhesive	14-B	Main office area, lavatory	NAD, NAD, NAD
15-A	4" Vinyl cove base, tan, and adhesive	15-A	Main office area, NE	Cove Base = NAD Adhesive/Glue - NAD
15-B	4" Vinyl cove base, tan, and adhesive	15-B	Main office area, E.	NAD, NAD
16-A	4" Vinyl cove base, white, and adhesive	16-A	Garage area, E., N. office, E. wall	Cove Base = NAD Adhesive/Glue = NAD
16-B	4" Vinyl cove base, white, and adhesive	16-B	Garage area, E., S. office, S. wall	NAD, NAD
17-A	Wallboard system (gypsum panel, joint-compound)	17-A	Main office area, NE, E.wall	Drywall = NAD Joint Compound = NAD
17-B	Wallboard system (gypsum panel, joint-compound)	17-B	Main office area, N., upper ceiling	NAD, NAD
18-A	Window glaze compound, off-white/lt. grey, brittle, chalky	18-A	2nd fl., NE exterior window area	NAD
18-B	Window glaze compound, off-white/lt. grey, brittle, chalky	18-B	Exterior garage area, NE	NAD

**Table 2  
Homogeneous Materials Sample Locations and Results  
Former Northfield Township Fire Department**

<b>HOMOGENEOUS AREAS</b>		<b>BULK SAMPLE LOCATIONS</b>		<b>ANALYTICAL</b>
<b>HA#</b>	<b>MATERIAL DESCRIPTION</b>	<b>SAMPLE #</b>	<b>SAMPLE LOCATION</b>	<b>PLM RESULTS</b>
19-A	Refractory cement, grey, cementitious	19-A	Garage area, SW, upper W. wall	NAD
19-B	Refractory cement, grey, cementitious	19-B	2nd fl., NE	NAD
20-A	Concrete masonry unit (CMU wall block), grey	20-A	Garage area, NE area	NAD
20-B	Concrete masonry unit (CMU wall block), grey	20-B	Garage area, SW area	NAD
21-A	Mortar joint, for CMU (HA-20)	21-A	Garage area, NE area	NAD
21-B	Mortar joint, for CMU (HA-20)	21-B	Garage area, SW area	NAD
22-A	HVAC duct vibration dampener, black vinyl-coated fabric	22-A	2nd fl., E.	NAD
22-B	HVAC duct vibration dampener, black vinyl-coated fabric	22-B	2nd fl., W.	NAD
23-A	Floor vapor barrier, black bituminous paper layer (underneath hardwood flooring)	23-A	2nd fl., NE	NAD
23-B	Floor vapor barrier, black bituminous paper layer (underneath hardwood flooring)	23-B	2nd fl., W.	NAD
24-A	4" Vinyl cove base, dk. grey, and adhesive	24-A	Garage area, SW, lavatory	Cove Base = NAD Adhesive/Glue = NAD
24-B	4" Vinyl cove base, dk. grey, and adhesive	24-B	Garage area, SW, lavatory	NAD, NAD
25-A	Vinyl sheet covering, tabletop & cabinet shelf liner, beige/tan sm. mosaic pattern, w/grey felt backing	25-A	2nd fl., S., kitchen area	Chrysotile - 15%
25-B	Vinyl sheet covering, tabletop & cabinet shelf liner, beige/tan sm. mosaic pattern, w/grey felt backing	25-B	2nd fl., S., kitchen area	N/A

**Table 2**  
**Homogeneous Materials Sample Locations and Results**  
**Former Northfield Township Fire Department**

HOMOGENEOUS AREAS		BULK SAMPLE LOCATIONS		ANALYTICAL
HA#	MATERIAL DESCRIPTION	SAMPLE #	SAMPLE LOCATION	PLM RESULTS
26-A	Sink under-coating, textured, lt. lavender	26-A	2nd fl., S., kitchen area	Chrysotile - 5%
26-B	Sink under-coating, textured, lt. lavender	26-B	2nd fl., S., kitchen area	N/A
27-A	Window gap insulation, fibrous batt w/paper & black coating	27-A	Garage area, NW	NAD
27-B	Window gap insulation, fibrous batt w/paper & black coating	27-B	Garage area, W.	NAD
28-A	Attic insulation, loose blown-in, cellulosic, lt. brown, fibrous	28-A	Main office area, above upper gypsum panel ceiling	NAD
28-B	Attic insulation, loose blown-in, cellulosic, lt. brown, fibrous	28-B	Main office area, above upper gypsum panel ceiling	NAD
28-C	Attic insulation, loose blown-in, cellulosic, lt. brown, fibrous	28-C	Main office area, above upper gypsum panel ceiling	NAD
29-A	Carpet adhesive, tan & mastic, black	29-A	Main office area, NE	Adhesive = NAD Mastic = Chrysotile 10%
29-B	Carpet adhesive, tan & mastic, black	29-B	Main office area, cent.	NAD, N/A
30-A	Carpet adhesive, yellow-tan	30-A	Garage area, W., N. office	NAD
30-B	Carpet adhesive, yellow-tan	30-B	Garage area, W., S. office	NAD
31-A	Floor leveling compound, grey, thin, w/residual adhesive & mastic	31-A	Main office area, cent.	Glue = NAD Leveling Compound = NAD Mastic = Chrysotile - 2%
31-B	Floor leveling compound, grey, thin, w/residual adhesive & mastic	31-B	Main office area, cent.	NAD, NAD, N/A

**Table 2  
Homogeneous Materials Sample Locations and Results  
Former Northfield Township Fire Department**

<b>HOMOGENEOUS AREAS</b>		<b>BULK SAMPLE LOCATIONS</b>		<b>ANALYTICAL</b>
<b>HA#</b>	<b>MATERIAL DESCRIPTION</b>	<b>SAMPLE #</b>	<b>SAMPLE LOCATION</b>	<b>PLM RESULTS</b>
32-A	Residual floor mastic, black	32-A	Main office area, cent.	Chrysotile - 2%
32-B	Residual floor mastic, black	32-B	Main office area, cent.	N/A
33-A	Sub-layer vinyl sheet flooring, tan w/grey felt backing & adhesive (below HA-11)	33-A	Main office area, lavatory	Vinyl Sheet = NAD Glue = NAD
33-B	Sub-layer vinyl sheet flooring, tan w/grey felt backing & adhesive (below HA-11)	33-B	Main office area, lavatory	NAD, NAD
34-A	Spray-foam sealant, yellow-orange	34-A	Garage area, S., upper wall hatches to office attic	NAD
34-B	Spray-foam sealant, yellow-orange	34-B	Garage area, S., upper wall hatches to office attic	NAD
35-A	Exterior, doorframe caulk, off-white, semi-flexible	35-A	SE doorway	NAD
35-B	Exterior, doorframe caulk, off-white, semi-flexible	35-B	NE doorway	NAD
36-A	Exterior, window lintel caulk, off-white	36-A	S. glass-block window area	NAD
36-B	Exterior, window lintel caulk, off-white	36-B	S. glass-block window area	NAD
37-A	Exterior, glass-block mortar joint, cementitious	37-A	S. glass-block window area	NAD
37-B	Exterior, glass-block mortar joint, cementitious	37-B	S. glass-block window area	NAD
38-A	Exterior, bulletin-board/notification panel frame caulk, grey	38-A	SE area	NAD
38-B	Exterior, bulletin-board/notification panel frame caulk, grey	38-B	SE area	NAD

**Table 2**  
**Homogeneous Materials Sample Locations and Results**  
**Former Northfield Township Fire Department**

HOMOGENEOUS AREAS		BULK SAMPLE LOCATIONS		ANALYTICAL
HA#	MATERIAL DESCRIPTION	SAMPLE #	SAMPLE LOCATION	PLM RESULTS
39-A	Exterior, window-frame caulk, lt. grey, flexible	39-A	E. area (newer window system)	NAD
39-B	Exterior, window-frame caulk, lt. grey, flexible	39-B	E. area (newer window system)	NAD
40-A	Exterior, window-frame caulk, grey/tan, brittle	40-A	NE area (older window system)	Chrysotile - 2%
40-B	Exterior, window-frame caulk, grey/tan, brittle	40-B	NW area (older window system)	N/A
41-A	Wallboard system (gypsum panel, joint-compound)	41-A	Garage area, N. office, W. wall	Wallboard System = NAD Joint Compound = NAD
41-B	Wallboard system (gypsum panel, joint-compound)	41-B	Garage area, S. office, S. wall	NAD, NAD
42-A	HVAC duct insulation, yellow fibrous matt w/grey plastic wrap	42-A	Garage area, E.-cent., above offices	NAD
42-B	HVAC duct insulation, yellow fibrous matt w/grey plastic wrap	42-B	Garage area, E.-cent., above offices	NAD
42-C	HVAC duct insulation, yellow fibrous matt w/grey plastic wrap	42-C	Garage area, E.-cent., above offices	NAD
43-A	Slate roofing shingles, grey, striated matrix	43-A	2nd fl., stored under stage	NAD
43-B	Slate roofing shingles, grey, striated matrix	43-B	2nd fl., stored under stage	NAD
44-A	Refractory compound, dk. grey	44-A	Garage area, W. upper W. wall, around metal duct	NAD
44-B	Refractory compound, dk. grey	44-B	Garage area, W. upper W. wall, around metal duct	NAD
45-A	Skim-coat plaster surfacing on CMU wall	45-A	Main office area, N. wall	Skim Coat Plaster/FC = NAD Plaster/BC = NAD

**Table 2**  
**Homogeneous Materials Sample Locations and Results**  
**Former Northfield Township Fire Department**

HOMOGENEOUS AREAS		BULK SAMPLE LOCATIONS		ANALYTICAL
HA#	MATERIAL DESCRIPTION	SAMPLE #	SAMPLE LOCATION	PLM RESULTS
45-B	Skim-coat plaster surfacing on CMU wall	45-B	Main office area, N. wall	NAD, NAD
45-C	Skim-coat plaster surfacing on CMU wall	45-C	Main office area, N. wall	NAD, NAD
--	<b>(1971 Bldg. Addition)</b>			
46-A	Wallboard system (gypsum panel, joint-compound)	46-A	SE office area, S. wall	Drywall = NAD Joint Compound = NAD
46-B	Wallboard system (gypsum panel, joint-compound)	46-B	Cent. office area, W. wall	NAD, NAD
47-A	Wall cavity insulation, pink fibrous batt w/paper layer & black coating	47-A	W. office area, W. wall	NAD
47-B	Wall cavity insulation, pink fibrous batt w/paper layer & black coating	47-B	W. office area, S. wall	NAD
48-A	1' x 1' Ceiling tile, adhered, w/groove pattern & brown adhesive	48-A	Cent. office area, above suspended ceiling system	Ceiling Tile = NAD Adhesive/Glue Pod = NAD
48-B	1' x 1' Ceiling tile, adhered, w/groove pattern & brown adhesive	48-B	NW office area, closet, above suspended ceiling system	NAD, NAD
49-A	Wall cavity insulation, yellow fibrous batt w/paper layer & black coating	49-A	W. office area, W. wall	NAD
49-B	Wall cavity insulation, yellow fibrous batt w/paper layer & black coating	49-B	W. office area, W. wall	NAD
50-A	Carpet adhesive, yellow-tan	50-A	W. office area, cent.	NAD
50-B	Carpet adhesive, yellow-tan	50-B	W. office area, cent.	NAD
51-A	Exterior, asphalt roofing shingles, w/grey grit	51-A	NE roof area	Asphalt Shingles - Grey = NAD Black Shingle = NAD

**Table 2**  
**Homogeneous Materials Sample Locations and Results**  
**Former Northfield Township Fire Department**

HOMOGENEOUS AREAS		BULK SAMPLE LOCATIONS		ANALYTICAL
HA#	MATERIAL DESCRIPTION	SAMPLE #	SAMPLE LOCATION	PLM RESULTS
51-B	Exterior, asphalt roofing shingles, w/grey grit	51-B	E. roof area	NAD, NAD
52-A	Exterior, bituminous sheet roof under-layment	52-A	NE roof area	NAD
52-B	Exterior, bituminous sheet roof under-layment	52-B	E. roof area	NAD
53-A	Exterior, wall panel sheathing, fibrous, brown	53-A	W. wall	NAD
53-B	Exterior, wall panel sheathing, fibrous, brown	53-B	S. wall	NAD
54-A	Exterior, tar-paper vapor barrier	54-A	W. wall	NAD
54-B	Exterior, tar-paper vapor barrier	54-B	S. wall	NAD
55-A	Exterior, window-frame caulk, off-white/lt. grey, semi-flexible	55-A	W. window area	NAD
55-B	Exterior, window-frame caulk, off-white/lt. grey, semi-flexible	55-B	W. window area	NAD

**Key: NAD = No Asbestos Detected N/A = Not Analyzed**

**Shaded rows indicate materials that are assumed or tested positive for asbestos.**